

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1130:212 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Honeywell Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models XLSG1-P, *XLSG1F-P, *XLSG1RF-P, XLSG1-H, XLSG1-HO, *XLSG1F-HO and *XLSG1RF-HO electronic horns; Models XLSG1-HV15, XLSG1-HV30, XLSG1-HV60, XLSG1-HV-75, XLSG1R-HV15, XLSG1R-HV30, XLSG1R-HV60, XLSG1R-HV-75, XLSG1-HOV15, XLSG1-HOV30, XLSG1-HOV60, XLSG1-HOV75, XLSG1-HOV110, *XLSG1F-HOV15, *XLSG1F-HOV30, *XLSG1F-HOV60, *XLSG1F-HOV75, *XLSG1F-HOV110, *XLSG1RF-HOV15, *XLSG1RF-HOV30, *XLSG1RF-HOV60, *XLSG1RF-HOV75 and *XLSG1RF-HOV110 horn strobes with or without suffix -R. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24-30 VDC
Candela: 15cd, 30cd, 60cd, 75cd, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as horns and horn/strobe lights for use with separately listed compatible fire alarm control units. For indoor use and wall mount only.

These horns can produce a distinctive 3-pulse temporal code pattern (for total evacuation) in accordance with NFPA 72, 1996 edition.

XLf: 7125-1388:231

*Rev. 08-25-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 25, 2002**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager